

Certificate of constancy of performance

0402-CPR-SC1328-17

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction products

Fire detection and fire alarm systems - Part 4: Power supply equipment

for fire safety use in fire detection and fire alarm systems for buildings, with specification as specified on page 2 in this certificate.

Product name: Milleteknik Rack and Milleteknik Nova

placed on the market under the name or trademark of

Milleteknik AB

Ögärdesvägen 8B SE-433 30 Partille, Sweden

and produced in the manufacturing plant

same as above

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in annex ZA of the standards

EN 54-4:1997, EN 54-4:1997/AC:1999, EN 54-4:1997/A1:2002 and EN 54-4:1997/A2:2006

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on 2017-12-18 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Issued by notified body 0402

The validity of this certificate can be verified on our website.

Lennart Aronsson
Product Certification Manager

Martin Tillander Project Manager

Certificate 0402-CPR-SC1328-17 | issue 1 | 2017-12-18

RISE Research Institutes of Sweden AB | Certification Box 857, SE-501 15 Borås, Sweden Phone: +46 10-516 50 00 certifiering@ri.se| www.ri.se







Certificate of constancy of performance

Specification

	T	T
Type definition	Power unit	Battery size [Ah]
RACK 27 150-1HE	HRP-300-24	28-200
RACK 27 250-2HE	HRP-600-24	45-300
RACK 54 70-1HE	HRP-300-48	14-100
RACK 54 130-2HE	HRP-600-48	20-200
NOVA 27 250-FLX	HRP-600-24	45-200
NOVA 27 150-FLX	HRP-300-24	20-200
NOVA 27 100-FLX	DRP-240-24	20-155
NOVA 27 50-FLX	DR-120-24	20-65
NOVA 13 100-FLX	DR-120-12	20-130
NOVA 27 100-XS2	DRP-240-24	14-120
NOVA 27 50-XS2	DR-120-24	7-70
NOVA 27 30-XS2	RS-75-24	7-42
NOVA 13 100-XS2	DR-120-12	14-120
NOVA 13 50-XS2	RS-75-12	14-84

Max

Certificate 0402-CPR-SC1328-17 | issue 1 | 2017-12-18